

ANCILLARY SERVICE REQUIREMENTS

In compliance with the Energy Regulatory Commission's (ERC) Order dated 01 December 2022, NGCP is posting the Ancillary Service Requirements and the existing Firm & Non-Firm contracted capacities as of **July 2026**:

Grid	REGULATING RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of July 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	627	0	0	257.78	257.78
Visayas	134	40	0	N/A	N/A
Mindanao	121	0	0**	68.61	68.61

*NPC Plants are certified only under Governor Control Mode (GCM) of operation.

Grid	CONTINGENCY RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of July 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	0	376.7	376.7
Visayas	150	0	0	83.44	83.44
Mindanao	138	0	210.7	80.71	80.71

Grid	DISPATCHABLE RESERVE				
	Required	Valid ASPAs (prior to CSP)		New ASPAs from CSP	Implemented ASPAs from CSP as of July 25, 2026 (Ave. MW)
		Firm	Non-firm	Firm (Ave. MW)	
Luzon	668	0	0	191.10	187.8
Visayas	150	0	0	44.27	5.5
Mindanao	138	7.5	0	129.15	129.15

Grid	REACTIVE POWER SUPPORT (No. of Units Contracted)		BLACK START SERVICE (Total MW)	
	Valid ASPAs (Prior to CSP)	New ASPAs from CSP	Valid ASPAs (Prior to CSP)	New ASPAs from CSP
Luzon	11	6	0	180
Visayas	0	16	0	184.5
Mindanao	0	18	225	196

Please note that the values remain the same since June 2026.

In summary, thirty-four (34) out of the thirty-six (36) ASPA Applications under the 2023 Competitive Selection Process (CSP) have been approved and issued with Final Authority by the ERC. The two (2) ASPAs which were not implemented as of date, despite receipt of ERC Provisional Authority are as follows:

- CIP II Power Corp. - Dispatchable Reserve in Luzon which has a pending Motion for Reconsideration filed with the ERC requesting for the re-evaluation of the interim approved rates and a Motion for the Termination of the ASPA.
- SPC Island Power Corporation - Dispatchable Reserve & Black Start Service for Visayas which has a pending Motion for the Termination of the ASPA.

NGCP is awaiting the final decision of the AS Providers for the ASPA implementation considering its filed Motions with the ERC, which are still pending for resolution.

Meanwhile, Therma Visayas, Inc. (TVI) has notified NGCP of the termination of its ASPA on 26 June 2026. Accordingly, NGCP filed to ERC, an Urgent Motion for Termination under Case No. 2023-050 RC, in compliance with the Final Authority issued by ERC under the said case, requiring its approval prior to the early termination of the ASPA.