

Competitive Selection Process for the Procurement of Ancillary Services to the Grid

BID BULLETIN NO. 2026- 01

This Bid Bulletin No. 2026-01 is hereby issued to announce an adjustment to the Bid Submission and Opening Schedules, as well as to announce the Reactive Power Support (RPS) and Black Start Service (BSS) requirements open for bidding for all Grids, in addition to the indicated capacities in the Terms of Reference under the Notice of Invitation to Bid No. AS-CSP-2026-01 published on February 18, 2026.

The Bid Submission and Opening Schedules are hereby adjusted:

| ACTIVITIES | ADJUSTED SCHEDULE |
|--|--|
| Deadline for Submission of Bids ("Bid Submission Deadline") | No later than 5:00PM of March 24, 2026 Luzon, Visayas and Mindanao (one date for all Grids) |
| Opening of Bids | Luzon: March 25, 2026 (10AM) Visayas: March 26, 2026 (10AM) Mindanao: March 26, 2026 (2PM) |

The Reactive Power Support (RPS) and Black Start Service (BSS) requirements for Luzon and Visayas are as follows:

| AS Type | Levels for Contracting | | |
|----------------------------|--------------------------------------|-----------------------------|--------------|
| RPS | Reactive power requirement per area: | | |
| | Area | Additional RPS Requirements | |
| | | MVAR Lagging | MVAR Leading |
| | North Luzon Area | 300 | 0 |
| | Cebu Area | 33.62 | 0 |
| | Panay Area | 40.88 | 0 |
| | Bohol Area | 4.92 | 0 |
| | Leyte-Samar Area | 0 | 40.4 |
| | Negros Area | 60 | 0 |
| | Northwestern Mindanao Area | 10 | 0 |
| | Southwestern Mindanao Area | 20 | 0 |
| Northeastern Mindanao Area | 20 | 0 | |

| BSS | At least two (2) black start plants per restoration highway | |
|----------------------------|--|---|
| | Area | Additional Black Start Units and Capacity Needed |
| | North Luzon Area | 2 x 50 MW |
| | Central Luzon Area | 1 x 50MW |
| | Metro Manila Area | 1 x 50 MW |
| | Southern Tagalog Area | 2 x 50 MW |
| | Bicol Area | 2 x 50 MW |
| | Panay Area | 2 x 20 MW |
| | Bohol Area | 2 x 20 MW |
| | Leyte-Samar Area | 1 x 20 MW |
| | Negros Area | 2 x 20 MW |
| | Lanao Area and North-Central Mindanao Area | 2 x 25 MW |
| | Northwestern Mindanao Area | 1 x 25 MW |
| | Northeastern Mindanao Area | 1 x 25MW |
| Southwestern Mindanao Area | 2 x 25 MW | |

CERTIFICATION

As Chairman of NGCP’s Third Party Bids and Awards Committee (“TPBAC”), I hereby certify that this Bid Bulletin No. 2026-01 for the Procurement of Ancillary Services to the Grid was discussed and approved by the TPBAC during the TPBAC regular meeting on February 27, 2026.

(sgd) **DARRYL LON A. ORTIZ**
TPBAC Chairman